CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7165-1130:117 Page 1 of 1

CATEGORY: Control Units (Non High-Rise)

LISTEE: Honeywell Inc., 1500 W. Dundee Rd., Arlington Heights IL 60004-1472

Contact: Bob Hodgson (847) 797-4403

DESIGN: Model Sentara 324. Local with shunt, auxiliary, remote station (protected premises) and

proprietary service. Refer to listee's data sheet for detailed product description and

operational considerations. System components:

Central control unit with communications processor

W1065A Data Gathering Module R8450A Accessory Relay Module

VIP7311 CRT Terminal SARA II Log Printer G00605 Log Printer

SPS-1-240-24 Uninterruptable Power Supply

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances

and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model/catalog number and UL label.

APPROVAL: Listed as a control unit for use with separately listed compatible initiating and indicating

devices.

This control unit does not generate a temporal pattern signal. If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1993 Edition is required, the control unit must be used with appliances that can generate the temporal pattern signal. Refer to manufacturer's Installation

Manual for details.

NOTE: 1. Burglary and other non-fire functions were not examined.

2. Formerly 7165-0069:102



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: JUNE 12, 2002 Listing Expires June 30, 2003

Authorized By: **DIANE K. AREND**, Senior Deputy

Program Manager